



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
Regional Public Health Water Analysis Laboratory, Tiruchirappalli-20.

From
Thiru.V.Ganesh, M.Sc.,
Chief Water Analyst (i/c),
Regional Public Health Water Analysis
Laboratory, Tiruchirappalli- 20.
Telephone No.0431-2332570

To
The Principal,
Sabarmathi Vidhyalaya
Public School (CBSE),
Eruthukaranpatty,
Kollapuram Road,
Ariyalur 621 713.

R.No.10/A3/2026/CWA/TRY/ Misc-03 & 04, Dated: 14.01.2026.

Sir,

Sub: Report on examination of water samples from the Sabarmathi
Vidhyalaya Public School (CBSE), Eruthukaranpatty, Kollapuram
Road, Ariyalur 621 713.collected on 07.01.2026

Two samples of water stated to have been collected on 07.01.2026 by Thiru.Aravindhan, Manager from the following sources points located within the premises of Sabarmathi Vidhyalaya Public School (CBSE), Eruthukaranpatty, Kollapuram Road, Ariyalur 621 713. (Source: Borewell water) were received at this laboratory on the same day from the addressee to assess their suitability for drinking purpose.

1. Water from borewell water tap nearby School Ground
2. Water from R.O unit tap nearby Head Master Room

The results of analysis are furnished overleaf.

1.Water from borewell tap near School Ground [M-03]

The sample of water is colourless and clear in physical appearance.

The chemical analysis reveals that, it is moderately hard and highly mineralized. However, it is considered as acceptable of chemical quality for drinking purposes.


It is of satisfactory bacteriological and biological quality for drinking purposes on this occasion.

2.Water from R.O unit tap nearby Head Mater Room [M-04]

The sample of water is colourless and clear in physical appearance.

Chemical analysis reveals that, it is very soft and less mineralized Even though it is usable the total hardness is only 10mg/l. The calcium and magnesium elements chemical are almost quality for drinking, removed from this water. The calcium and magnesium are very essential minerals for healthy living of human beings. Consumption of this type water for a prolonged time shall be deleterious to the health of the consumers including growing children.

THE PRINCIPAL
SABARMATHI VIDHYALAYA PUBLIC SCHOOL,
ERUTHUKARANPATTY, KOLLAPURAM ROAD,
ARIYALUR - 621 713 TN, INDIA



Hence, it is advised that, the supplier of the R.O plant should be contacted immediately along with the copy of this report, to set right the R.O plant in such a way that, the water contains atleast a minimum 30mg/l of total hardness, So as to have some amount of calcium and magnesium in the outlet of R.O plant, which are very essential for a healthy life.

It is of satisfactory bacteriological and biological quality for drinking purposes on this occasion.

The R.O plant should also be maintained periodically as per the supplier's manual to get hygienic safe of water.

The Sump/OHT should be cleaned with strong solution of bleaching powder atleast once in a month to ensure hygienic condition.

For Chief Water Analyst, (i/c)
Regional Public Health Water Analysis
Laboratory, Tiruchirappalli-20.

Copy to :

1. Lab
2. File

N. S. S. S. S.
THE PRINCIPAL
SABARMATHI VIDHYALAYA PUBLIC SCHOOL,
ERUTHUKARANPATTY, KOLLAPURAM ROAD,
ARIYALUR, ARIYALUR - DT. 621713.TN-INDIA



RESULTS OF EXAMINATION OF SAMPLES OF WATER

From: Sabarmathi Vidhyalaya Public School (CBSE), Eruthukaranpatty,
Kollapuram Road, Ariyalur 621 713
Collected by:- Thiru.Aravindhan, Manager

Date of collection	07.01.2026				
Date of Receipt	07.01.2026				
Sample Number	M- 03	M- 03			
Source as per label [Borewell]	Directly from Borewell	Tap at R.O unit			
Bacteriological Examination					
Total colonies per ml. On agar at 37°C	10	5			
MPN of Coliform bacteria per 100ml.	-0-	-0-			
Nature of Coliform Bacteria Isolated					
Physical Examination					
Colour	Colourless	Colourless			
Turbidity	5	2			
Smell	None	None			
Total solids	1010	40			
Carbonate hardness as CaCO ₃	240	10			
Non-Carbonate hardness as CaCO ₃	0	0			
Total hardness as CaCO ₃	240	10			
Chlorides as Chlorine	112	8			
Ammoniacal nitrogen	--	--			
Albuminoid nitrogen	--	--			
Oxygen absorbed (Tidy's test)	0.40	0.16			
Nitrate -nitrogen	4.0	0			
Acidity/Alkalinity } Phenolphthalein s CaCO ₃ } Methyl Orange	0	0			
	496	22			
Fluoride as Fluorine	0.6	0			
pH Value	6.9	6.6			
Iron as Fe	0.05	0			
Ferrous	--	--			
Manganese as Mn.	--	--			
Nitrite nitrogen	Trace	Trace			
Sulphate	Trace	Trace			
Phosphate	Trace	Trace			
Toxic substance	--	--			
Electrical conductivity (Reciprocal megohms per Cm ³ at 20 °C)	1450	50			
Microscopical Examination	Amorphous matter	Amorphous matter			

N. S. S. S. S.
THE PRINCIPAL
SABARMATHI VIDHYALAYA PUBLIC SCHOOL,
ERUTHUKARANPATTY, KOLLAPURAM ROAD,
ARIYALUR, ARIYALUR - DT. 621713.TN-INDIA.





DEPARTMENT OF PUBLIC HEALTH & PREVENTIVE MEDICINE

SCHOOL SANITARY CERTIFICATE

Appendix -3
(Chapter III Rule: 24)
Tamilnadu Educational Rules

Year : 2018-19

I hereby declare that I have inspected the school SABARMATHI VIDHYALAYA
PUBLIC SCHOOL (CBSC), ERUTHUKARAN PATTI, ARIYALUR. And its premises on the day of
30.06.2018

and

Certify

- ❖ That the accommodation provided for each of the several classes is sufficient for the minimum number of Pupils taught therein and is properly ventilated and lighted;
- ❖ That the building is maintained in substantial repair;
- ❖ That is neat and clean;
- ❖ That the latrine arrangements are adequate and satisfactory;
- ❖ That the supply of drinking water is wholesome; and
- ❖ That in all other necessary respects the sanitation is good.

This Certificate is valid for the period of One year from the date of issue.

[Signature]
Counter Signed *26/07/18*
DEPUTY DIRECTOR OF
Health Services
Ariyalur - 621 704

Signature
[Signature]
(K. Vakheer)
Block Health Supervisor
Govt. Primary Health Centre
Kadugur Ariyalur

[Signature]
THE PRINCIPAL
SABARMATHI VIDHYALAYA PUBLIC SCHOOL,
ERUTHUKARANPATTY, KOLLAPURAM ROAD,
ARIYALUR, ARIYALUR - DT. 621713, TN-INDIA



பொது சுகாதாரம் மற்றும் நோய்த்தடுப்பு மருந்துத்துறை

அனுப்புநர்

மரு. வி.சி.ஹேமாசந்த் காந்தி, எம்பிபிஎஸ், டிபிஎச், எம்பிஎ, (மமே)
துணை இயக்குநர் சுகாதாரப் பணிகள்,
அரியலூர்.

பெறுநர்

தா.நா.நர்,
கயங்குடி வித்யாலயா பப்ளிக் பள்ளி
எடுதுகரணப்பட்டு

ஒழு.எண்: 3786/அ/2018 நாள்: 16/2018

பொருள்: பொது சுகாதாரம்- அரியலூர் சுகாதாரப்பகுதி மாவட்டம் - சுகாதார சான்று வழங்குவது தொடர்பாக.

பார்வை: 1. தங்களின் கடித நாள்: 12/06/18

2. வட்டார சுகாதார மேற்பார்வையாளர், ஆரம்ப சுகாதார நிலையம், கடுகை
ஆய்வறிக்கை நாள்: 30/06/18

பார்வை-2ல் காணும் வட்டார ஆரம்ப சுகாதார நிலைய வட்டார சுகாதார மேற்பார்வையாளரின் ஆய்வறிக்கையின் அடிப்படையில் பார்வை 1 ல் காணும் கடிதம் வாயிலாக தாங்கள் கேட்டுக்கொண்டதற்கு கயங்குடி வித்யாலயா பப்ளிக் பள்ளி, சுகாதார சான்று கீழே குறிப்பிட்டுள்ள நிபந்தனைக்கு உட்பட்டும் வருங்காலங்களில் பின்வருமாறு பராமரிப்பு செய்து வருமாறு அறிவுறுத்தி சான்று வழங்கப்படுகிறது.

1. பள்ளி சுற்றுப்புறத்தை தூய்மையாக வைத்துக்கொள்ளவேண்டும்.
2. மழை நீர் மற்றும் கழிவு நீர் தேங்காத வண்ணம் சுற்றுப்புறத்தை அமைக்கவேண்டும்.
3. பள்ளி மாணவர்களுக்கு தேவையான கழிவறைகள், பாலினவாரியாக அதிகப்படுத்துதல் வேண்டும்.
4. மேல்நிலை நீர் தேக்கத்தொட்டி முறையாக, சுத்திகரிக்கப்பட்டு குளோரினேசன் செய்யப்பட்ட குடிநீர் வழங்கப்பட வேண்டும்.
5. எளிதில் தீ பிடிக்கக்கூடிய பொருட்கள் இருக்காத வண்ணம் பார்த்துக்கொள்ள வேண்டும்.
6. வளாக எல்லையில் புகைப்பிடிப்பதை தடுக்கும் அறிவிப்பு பலகை வைக்கவேண்டும்.
7. குப்பைகள் மக்கும் மற்றும் மக்கா என தரம்பிரித்து அப்புறப்படுத்தவேண்டும்.
8. பள்ளி சுற்றுப்புறத்தில் காய்ச்சல் பரவுவதை தடுக்கும் வகையில் தேவையற்ற பொருட்களில் மழைநீர் தேங்காதவண்ணம் அப்புறப்படுத்தவேண்டும்.
9. ஒவ்வொரு ஆண்டும் சுகாதார சான்றிதழ் புதுப்பித்தல் வேண்டும்.
10. புகையில்லா வளாகம் என்ற அறிவிப்பு பலகை இருக்க வேண்டும்.
11. குழந்தை தொழிலாளர்கள் அமர்த்தப்படக் கூடாது.
12. பொது சுகாதாரத்துறையின் மூலம் செயல்படுத்தும் நலத்திட்டங்களுக்கு முழு ஒத்துழைப்பு அளிக்க வேண்டும்.

நகல்

வட்டார சுகாதார மேற்பார்வையாளர் அரசு ஆரம்ப சுகாதார நிலையம்,

கடுகை

துணை இயக்குநர் சுகாதாரப்பணிகள்
அரியலூர்
26/6/18

N.S. - 111111
THE PRINCIPAL
SABARMATHI VIDHYALAYA PUBLIC SCHOOL,
ERUTHUKARANPATTY, KOLLAPURAM ROAD,
ARIYALUR, ARIYALUR - 621713.TN-INDIA





GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00125ARI15011

Issued Date : 13-11-2025

Organization Type : Educational Institutions

Expiry Date : 12-11-2026

Name of the Organization : SABARMATHI VIDHYALAYA PUBLIC SCHOOL

Address : Eruthukaranpatty, Kollapuram road, Ariyalur

I, SHREE NEELIYAMMAN EDUCATIONAL TRUST owner/manager of the SABARMATHI VIDHYALAYA PUBLIC SCHOOL functioning as Educational Institutions located at Ariyalur (n) in Ariyalur district hereby declare that

- This Self-Declared Sanitation certificate is valid from 13-11-2025 to 12-11-2026 and will be renewed every year prior to the expiry of the current certificate with updated information.
 - Our premises can accommodate 1032 people/pupils and has 66 urinals and 68 toilets which is proportionate to the number of users as per government norms.
 - 10 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
 - The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
 - There is no potential mosquito breeding area on the premises.
 - The premises have adequate drinking water fountains on each floor of the premises.
 - The self-declared certificate is displayed prominently on the premises along with the protocol
- The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



Signature of the Owner/Manager



(அ) TN00125ARI15011 என்ற தனிப்பட்ட சான்றிதழ் என்னை

<https://www.tnsevai.in.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு கொண்டு சரிபார்க்கவும்

(அல்லது)

(ஆ) கைப்பேசியில் பார்ட்கொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்

Genuineness of the certificate can be verified by.

உறுதிப்படுத்த இணையதளத்தில் TN00125ARI15011 ன் URL

<https://www.tnsevai.in.gov.in/edistrict/CheckStatus/Certificate/>

(அ)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.

THE PRINCIPAL
SABARMATHI VIDHYALAYA PUBLIC SCHOOL,
ERUTHUKARANPATTY, KOLLAPURAM ROAD,
ARIYALUR, ARIYALUR - DT. 621713, TN-INDIA.

